



Great Lakes Case & Cabinet Co., Inc.


Thank

You

for your
business!

www.weRackyourWorld.com



NEMA Wall Mount - N12 Series **Installation Instructions**



www.weRackyourWorld.com

1-866-TRY-GLCC (879-4522)



NEMA 12 WALL MOUNT ENCLOSURES

PART NO.	H	RMU	WT. CAP.	SHIP. WT.
GL240N12	24.00"	12	150 lbs	105 lbs
GL360N12	36.00"	19	250 lbs	140 lbs
GL480N12	48.00"	26	300 lbs	175 lbs


Thank you for purchasing a Great Lakes Case & CabinetCo., Inc. NEMA wall mount enclosure. The enclosure has been fully assembled at the factory, all you need to do is mount it to the wall.

Instructions:


The mounting holes on this wall mount are designed for 1/4" hardware, 16" on center. Internal rails are adjustable every 1".




TOP VIEW



FRONT VIEW



RIGHT SIDE VIEW



When installing a Great Lakes Swing Rack or Wall Mount to materials such as wood, cinder block, concrete, etc., please consider the load capacity within the swing rack or wall mount structure, and be certain to check with local authorities to determine the appropriate hardware requirements for these conditions. Because wall compositions may vary at different installation sites, Great Lakes cannot warrant the fitness or suitability of any installation instructions or installation hardware it may provide for swing rack or wall mount enclosures. Great Lakes hereby **DISCLAIMS ALL WARRANTIES, EXPRESS AND IMPLIED, INCLUDING THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, REGARDING THE SUFFICIENCY, FITNESS OR SUITABILITY OF ANY INSTALLATION INSTRUCTIONS OR INSTALLATION HARDWARE GREAT LAKES MAY PROVIDE FOR SWING RACKS AND WALL-MOUNTED ENCLOSURES.** Great Lakes recommends that an experienced maintenance and/or technical person be consulted regarding the proper wall-mounting hardware and procedures to be used for the anticipated load capacity of the swing rack or wall mounted enclosure.

Product specifications are subject to change without prior notice.