



SPECIFICATION GUIDELINE FOR WM Series Wall Mounts

General

The Wall mount enclosure must be UL listed to UL60950-1 (Standard for Information Technology and Communications Equipment, Cabinet, Enclosure and Rack Systems.)

Dimensions shall be 24, 36 or 48”H x 21.25”W x 24.50”D (24” H available in 18”D)

Unit must be 3 “piece” sectional design using a continuous hinge between. Front and rear sections latch with “push-pull” catch and each section must lock independently. Wall mount to be reversible allowing for right or left hand swing. Top and bottom set up to accept fan assembly.

Black powder coat finish on 14-gauge steel.

Manufacturer must be ISO 9001:2000 registered.

Mounting -The base unit must have 2 pair of 19” rack mount rails that are tapped 12-24. Adjustable front to rear.

Cable Access -Rear section to have knockout in center back and top/bottom for conduit sizes 1, 2 & 3”. In addition integrated horseshoe knock-out must be standard for running cables that are already terminated onto a patch panel.

Doors -Doors to be plexi-glass or solid. Base unit must have gasketing for the doors.

Sides -Sides of center section to have venting slots on top and bottom

Cable Management- all 19” rack mounted cable management to be installed, preferably on the rear rails.

Power Strips- all 19” rack mounted power strips to be installed on the rear rails.

Fans- 2 low profile 75cfm fans to be installed in cabinet. (When ordered)

